



FIRE SAFE TEST CERTIFICATE

This certificate is issued to

M/s. VALVEMATICS ENGINEERING PVT. LTD.

Plot No. 5 & 6, Shah Industrial Estate, Nangargaon, Lonavla-410401.
Maharashtra. India.

to certify that at their request the undersigned surveyor to GLIS (I) Pvt. Ltd., attended their works at Plot No. 5 & 6, Shah Industrial Estate, Nangargaon, Lonavla-410401. Maharashtra. India., on 07th May, 2019, for the purpose of witness of fire safe test of 2Way-3PC-Ball Valve.

The scopes of Inspection & Approval are as below.:

STANDARD SPECIFICATION : API 607 7th Edition, June 2016

TECHNICAL SPECIFICATION

Design / Mfg. Standard : ASME B 16.34
Construction : 2Way 3PC Ball Valve
Size : 2" (DN 50)
Class : 150#
Valve Serial No. : VM0587
Valve Drg. No. : VEPL/BV/FE/2"/150/00 Rev 00

MATERIAL OF CONSTRUCTION

Body/ End Piece : ASTM A216 Gr. WCB
Ball : ASTM A276 Gr. SS316
Stem/Gland : ASTM A 276 Gr. SS316
Body Seal/Seat : PTFE
Gland Packing : PTFE
Stud : ASTM A 193 Gr. B7
Nut : ASTM A 194 Gr. 2H

Conclusion: 2Way 3PC Ball Valve, Sr. No. VM0587 punched on flange had successfully passed fire safe test as per procedure outlined in API 607, and witnessed by undersigned GLIS (INDIA) Pvt. Ltd., Surveyor on 04th February 2019. This test results conforming with the specification

Note : i) GLIS (I) Pvt. Ltd., is to be notified of any changes to the design of this valve that may affect the Validity of this Certificate.

Other Sizes Qualified : 2" and below 2 ½", 3" & 4"
Other Pressure Class Qualified : 150# & 300#

Date of Issue: 07th May, 2019.
 Date of Expiry: 06th May, 2022.

Issued at:
 Ahmedabad

07.05.2019

J.C. Panchal

Place

Date

Manager-Inspection

